



EUROPEAN INSPECTION AND CERTIFICATION COMPANY S.A.

CERTIFICATE OF CONFORMITY

FULLNESS EXAMINATION OF TECHNICAL FILE

Certificate No.	: MA2610
Issue Date	: 15/01/2026
Expiry Date	: 14/01/2028
Applicant	: ANAXI TECHNOLOGIES LTD
(Name & Address)	: 27, Old Gloucester Street, WC1N 3AX, LONDON, United Kingdom
Manufacturer	: Same as applicant
Product Description	: Generator + lighting system 20kVA
Model(s)	: ALMI-4M1000
Specification(s)	: See ANNEX I for details
Directive(s)	: Machinery Directive 2006/42/EC
Standard(s)	: EN ISO 12100:2010, EN 60204-1:2018, EN 60529:1991

This is to certify that, upon the relevant application of the above mentioned applicant, EUROCERT as Third Party Authority has reviewed the Technical Construction File of the described product which found to fulfill the basic health and safety prerequisites of above mentioned Directive(s)

NOTE:

- The manufacturer should issue a Declaration of Conformity according to the basic requirements of the applicable and relevant directives.
- The CE marking can be affixed on the above mentioned product with the manufacturer's responsibility, if all relevant and applicable directives are complied with.
- All modifications to the Technical File should be first submitted to the Third Party Inspection Authority to ensure further validity of this attestation
- This certificate is valid only for the product and configuration described and in conjunction with the technical data detailed above.



Third Party Authority Stamp

On Behalf of EUROCERT

GEORGE N. SIFONIOS
Director of Development

89 CHLOIS STR. & LIKOVRISEOS, 144 52 METAMORFOSI, ATHENS, GREECE
Tel.: ++30 210 62.52.495, 30 210 62.53.927 - Fax: ++30 210 62.03.018
Internet site: www.eurocert.gr - e-mail: info@eurocert.gr



EUROPEAN INSPECTION AND CERTIFICATION COMPANY S.A.

ANNEX I to MA.2610

GENERATOR + LIGHTING SYSTEM 20KVA

MODEL: ALMI-4M1000

TECHNICAL PARAMETERS:

Generator		
Phase	Type	1-phase
Fuel	Type	Diesel
Output Voltage	VAC	220
Rated Power	kVA	20
Rated Frequency	Hz	50
Control Panel	Type	Digital Control Panel
Auxiliary Output	kVA	13.8
Auxiliary Output Quantity	Unit	1
Auxiliary Output Voltage	VAC	220
Fuel Tank Capacity	Lts	80 ± 1%
Dimension & Weight		
Dimension(L*W*H)	Mm	3800*1550*2600
Weight	Kg	1550
Engine		
Brand	Name	Perkins
Speed	Rpm	1500
Cooling System	Type	Water Cooled
Alternator		
Brand	Name	Leroy Somer
Insulation/Enclosure Protection	Class/IP	H/23
Lighting & Mast		
Lamps	Type	Metal Halide
Floodlights	N° x W	4X1000
Lampshade's Degree of Protection	IP	54
Illuminated Area	Sqm	4200 ± 5%
Maximum Height	M	9 ± 3%
Lifting System	Type	Manual
Mast Rotation	Degree	Manual 340
Maximum Wind Speed	Km/H	110 ± 5%
Trailer & Enclosure		
Signal Lamp		Yes
Socket	Units	2
Tires	Type	15" Off road
Brake	Type	Manual
Stabilizer Legs	Type	Manual
Stabilizer Legs Quantity	Units	4
Control panel		
Control and Protection Panel		Comap IntelliLite 4 AMF 25

89 CHLOIS STR. & LIKOVRISEOS, 144 52 METAMORFOSI, ATHENS, GREECE

Tel.: ++30 210 62.52.495, 30 210 62.53.927 - Fax: ++30 210 62.03.018

Internet site: www.eurocert.gr - e-mail: info@eurocert.gr